



Public Works Info - NE Plant Overflow

Overflow at the Northeast Plant – Dec. 3, 2018

On the evening of December 3, approximately 226,000 gallons of reclaimed water was discharged from the Chlorine Contact Chamber due to operator error.

The chlorinated water spill was contained to the plant property and on-site detention pond.