

Spill notification -- 11/23/2018

Temporary ductile iron pipe -- installed by contractor at Southwest Water Reclamation Facility (located at 3800 54th Av. S. St. Petersburg) broke and discharged 10,000 Gals of fully treated and disinfected reclaimed water.

All water contained on site.

Contractor made repairs and secured site.