

Spill notification -- 12/08/2018

Temporary pipe -- installed by contractor -- at Southwest Water Reclamation Facility (located at 3800 54th Av. S. St. Petersburg) broke and discharged 5,000 Gals of fully treated and disinfected reclaimed water between 6:10 and 6:30 pm December 7, 2018.

All water was contained on site.

Contractor made repairs and secured site.